



Town of Miami Lakes

ITB 2017-13

Furnish & Install HVAC System for Mary Collins Community Center

Addendum #1

Due Date: February 24, 2017

This addendum is incorporated into and made a part of the Invitation to Bid (“ITB”). The following may include clarifications, revisions, additions, deletions, or answers to questions received relative to the ITB, which take precedence over the ITB documents. Underlined word(s) indicate additions. Deletions are indicated by strikethrough.

Clarifications:

- 1. Section A, Notice to Bidders, Minimum Qualification Requirements is hereby revised as follows:

To be eligible for award of this project, bidders shall:

- 1. Possess a valid Miami-Dade County Air Conditioning Mechanical limited or unlimited license or State of Florida Class A or B Air Conditioning Contractor or Mechanical license;
- 2. Section D, Special Terms and Conditions, Article D1, Scope of Work is hereby revised as follows:

The scope of work includes the furnishing and installation of:

- 1. Condensate pump with overflow switches; insulated copper refrigeration lines; pvc condensate drain lines; power wiring, conduits, boxes and terminations; electrical disconnect switches; a new aluminum stand with approved Notice of Acceptance; patch and seal penetrations through existing wall; start-up of air conditioning system; and provide plans for permitting.

Acknowledgement:

Name of Signatory

Signature

Title

Name of Bidder

Date

Thomas Fossler
Procurement Specialist